## FORM -I PART C6

# APPLICATION FOR OBTAINING NOC FROM A.P. FIRE SERVICE DEPARTMENT

SI. No.	Particulars of building	Required as per NBC of India and other Regulations	Actually Available	Deficit
1.	Name and Address of the Owner			
2.	Location and Address of the Bldg.			
3.	Area of the Site (In Sq. Mtrs.)	1000 Sq.Mtrs. (Minimum)		
4.	Area of the Building (Industry) (in sq.mtrs.)			
5.	Type of Occupancy : (Ref. Clause - 4 Part - IV of NBC)			
6.	Height of the Building (in mtrs.)	Maximum permissible 18 mtrs. only		
7.	Height of each floor (in mtrs.)	2.90 mtrs. (minimum)		
8.	No. of Inhabitants / Occupants			
9.	Means of Escape :			
	a) Internal Stair cases	Two (minimum)		
	b) External Stair Case	One (minimum)		
	c) Width of Stair Case	1.5 mtrs.		
	[As per Part-IV Clause 8 of NBC of (india)] No. of Exits width of each exit			
10.	Open Spaces all around the bldg:			
	North			
	East			
	South			
	West			
	(As per Part-III Clauses 8.2.3.1 of NBC of India)			
	Min. 06 Mtrs All around the Bldg. For every rise of 3 mtrs. Ht. Add 01 Mtr.			
11.	Level of the Ground	Levelled		

SI. No.	Particulars of building	Required as per NBC of India and other Regulations	Actually Available	Deficit
12.	Means of Access to premises (As per Part III Clause 4,6 of NBC)	4.5 mtrs One (Minimum)		
13.	Width of Exit from Premises	4.5 mtrs One (Minimum)		
14.	Fire Detection System : (Automatic) (As per Clause 7,10.2. Table 20 of Part-IV of NBC)			
	a) Smoke			
	b) Heat			
	c) Gas			
15.	Fire Alarm System :			
	a) Manual			
	b) Automatic (24 Mtrs. above)			
	c) 01 Point for 22.5 mtrs. Travel distance			
	d) Break Glass type			
	e) Easily Noticeable			
	(As per Clause 7.10.2. Table 20 of Part-IV of NBC)			
16.	Automatic firefighting system :			
	(As per Clauses 7.10.2 Table 20 of Part-IV of NBC	a) Sprinkler		
		b) Foam		
		c) CO2		
		d) DCP		
17.	Underground Static Water Tank (As per Part-IV Clause 7.10.6 Table 20 of NBC of India)	01 lakh litres Capacity		
18.	Fire Service Inlet: (As per Part IV Clause 7.10.6 (b) of NBC of India)	One - 4 Way		
19.	Courtyard Hydrants: (As per Part IV Clause 7.10.2 Table 20 of NBC of India) one hydrent point for every 22.5 mtrs.			
20.	Fire Pumps :			
	a) Electrical 15 mtrs. To 30 mtrs. Ht.	1630 / Min.		
	30 mtrs. To 45 mtrs.	2850 / Min.		
	b) Diesel	2850 / Min.		
	(As per Part-IV Clause 7.10.6. Table 20 of NBC of India)			

SI. No.	Particulars of building	Required as per NBC of India and other Regulations	Actually Available	Deficit
21.	Transformer :	Protection Measures		
		1. 45 Ltrs. Foam Trolley		
	(As per Part-IV Appendix D-1.1.16 of NBC of India)	2. Fencing		
		3. Soak Pit		
22.	Lightning Protection : (As per Part-IV. Appendix D-3 of NBC of India)	One		
23.	Control Room : (As per Part-IV. Appendix D-5 as per NBC of India)	One		
24.	Whether the Hydraulic Platform can be moved all around the bldg.			

Place	:

Date : Signature of the applicant

No.			

## FORM - I PART - C6

### APPLICATION FOR NOC FROM FIRE SERVICES DEPARTMENT

### **Fee Structure**

Amount to be paid : For all multistorey buildings (15mtrs. and above)

Fire precaution fund @ Rs. 10/- for sq.mtr of builtup area

Mode of payment : D.D. in favour of AP Fire Services Department of the concerned

District

Check Slip					
1.	Part	: C6 of Form-I	3 copies + 1 copy to nodal agency	]	
2.		ns of the Industry with open space ound and exits with widths	5 copies	]	
3.	Fire safety system proposed and the places where they are proposed to be installed (to be indicated in the plan)				
	<ul> <li>a) Fixed Fire Fighting Installations - Viz. Automatic detection and alarm system, sprinkler system, foam/drypowder installations, manual fire alarm system, water spray systems etc.</li> </ul>				
	b)	Extinguishers			
4.	Measurement of the Fire Water Sump				
5.	Details of fee paid :				
	D.D	.No. Amount	Date		